

Public engagement in Energy solutions - New heating system in the eco-village Munksøgård

By Kenneth Karlsson

keka@dtu.dk

Energy Crossroads, Studenterhuset, Monday 8 May 2017




Some facts..... www.munksoegaard.org

- The house was build in year 2000 - at that time 15% better than the building regulation heat loss wise
- 5 groups of 20 dwellings erected around an old farm building
- Different owner forms and age groups (youth group, senior group and three mixed groups)
- Focus has been on local involvement: local waste water treatment, urine separation toilets and local heating system based on wood pellet boilers and oil back up etc.
- Democratic structure: Common meetings, 2 represents from each group forms the board and a general assembly is the highest authority





Existing heating system







Decision process


1. An “expert” group was established in spring 2014 to describe the different technical solutions, their costs and impacts. Posters have been produced describing each solution. This group was supported by a professional energy consultant.
2. All residents were invited on a meeting in June 2015 where posters and the solutions were presented. The residents were able to ask questions to the “expert group”.
3. The posters were put up in each of the five common houses during the summer of 2015 to encourage people to discuss pros and cons of the different solutions.
4. After summer of 2015 a full day workshop was organized. The workshop ended up with an indication of the preferred solution.
5. Shortly after this workshop the matter was treated on the general assembly meeting and a voting between the solutions was carried out.
6. A detailed feasibility study is then started for the chosen solution.
7. The new heating system will be implemented.

Possible solutions

- Improved wood pellet boiler
- Local heat pumps
- Connect to district heating



kr/år	VP	TræOpt.	Fjernvarme
Sparet ifht nuværende syst.	*****	48,518	-80,257
Areal til VP jordslanger m2	17,250		
Lev. ud af varmecentr.(MWh)	780	839,038	*****
Lev. ud af varmecentr.(MWh)	0	913,213	*****
Andel træpiller	95%	TræOpt.	Varmerpris
Lev. ud af varmecentr.(MWh)	780	790,520	*****
Fjernvarme lev. til central	780	919,295	*****



Ved at rette i de gule felter kan man lave nye scenarier for Munksøgårds varmesystem.

HUSK kun at rette i de gule felter ellers ødelægges formler eller data.


Iarket "Sammenligning" kan resultaterne for scenarierne ses.

	Ungdom Ejer	Senior	Andel	Familie
Rumvarmeforbrug pr. m2	52.82	50.01	*****	*****
Solfanger	20	22	15	20
Lokal varmepumpe	113	197	104	137
Varmerpumpe dækning	100%	100%	100%	100%
Tab rumvarmenet	26%	22%	21%	21%
Tab varmt vands cirkulation	15%	36%	39%	35%
Rumtemp ned i grader C	0	0	0	0
Varmerbesparelse	0%	0%	0%	0%
Varmtvands forbrug ned	0%	0%	0%	0%
Sænkelse af frem og retur temp.				
Mindsket tab hoved FVnet	20%			

Forkortelser

FV = fjernvarme
VV = varmt vand
Træp = træpiller
VP = varmepumpe
FV rum = fjernvarme til rumvarme

113	196	103	137	123
95	162	84	115	103



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe



113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Tab VV cirkulation og tank 14


FV rum 103

VV forbrug 26

Rumvarme 82

Tab rumvarme kred 21

123 Varmepumpe





113	196	103	137	123
95	162	84	115	103

Familie

Solfanger 20

FV til VV 20

Improved wood pellet boiler



Improved wood pellet boiler

Pros	Cons
Relatively cheap solution	Professionals are needed for repairs and maintenance and regulation
Low emission of CO ₂ (only from transport)	Risk of breakdowns mainly due to wood pellet transport system
More stable system	Big trucks with wood pellets arrive once a week in the cold period
Improved local air quality	Depends on limited biomass resources
Locally known technology	Noise problem from flue gas system


Local heat pumps





Local heat pumps

Pros	Cons
No noise	Needs thorough monitoring and regulation
Low CO ₂ emission (from electricity production)	Will not be able to deliver enough heat in the coldest periods (needs electric supplement)
Less maintenance	Leakage in underground pipes is difficult to find and repair
No local air pollution	A big ground area is needed for the underground pipes
Fits well into the future Danish energy system	

Connect to district heating




Brændselsfordeling for fjernvarmeproduktionen:





Connect to district heating

Pros	Cons
No noise	Heat price is set by Roskilde Forsyning (the local distribution company)
No local air pollution	Breakdown on main district heating grid will influence heat supply at Munksøgård
Very little maintenance	
Minimum need for monitoring and regulation	
Fits well into the future Danish energy system	


Comparison of solutions - private costs



Comparison - emissions




Comparison - Socio-economic health costs



Now you vote 😊




Voting result from Munksøgård General Assembly



Wood Pellet Boiler
36%



Local Heat Pumps
35%




District Heating
29%


What would be the socio-economic optimal solution?

TIMES-DK is an energy system optimization model developed by DTU and DEA. It includes all sectors and all energy carriers.

It has two regions DK-E and DK-W which are subdivided into Urban, Suburban and Rural areas. Within each of these areas it describes 12 building types.



Categorizing the Munksøgård buildings




Detached buildings
before 1972

Detached buildings
after 1972


Multi-story buildings
before 1972

Multi-story buildings
after 1972


Costs of connecting to district heating




Costs of heat savings



Modelling of heat supply to the buildings



Heat supply to Munksøgård building categori



District heating production in central area DK-E

